



RACKING OVER 8 FT HIGH REQUIRES A SEPARATE PERMIT

MUST MAINTAIN EXISTING 1/2\"/>

PROVIDE EMERGENCY LIGHTING AS PER CODE

17-49989

THESE PLANS HAVE BEEN REVIEWED FOR SUBSTANTIAL COMPLIANCE WITH THE MINIMUM STANDARDS OF THE B.C. BUILDING CODE, CURRENT EDITION, DEVELOPMENT PERMITS WHERE APPLICABLE AND ALL RELEVANT SURREY BY-LAWS. DETAILS ON THE PLANS WHICH EXCEED THE ABOVE LISTED MINIMUM STANDARDS ARE NOT CONSIDERED IN THE ISSUANCE OF THIS PERMIT.

NOTE: THE REVIEW OF THESE PLANS DOES NOT GUARANTEE COMPLIANCE.

DATE: MAR 19 2018 PLAN CHECKER [Signature]

PROCESSED
MAR 19 2018
City of Surrey

RECEIVED
JAN 10 2018

A1

OK GLOBALNET TRADING LTD AT 190-19288 22ND SURREY

FLOOR PLAN SCALE: 1/2"=1'-0" MAXIMUM OCCUPANT LOAD: 10 PERSONS
NOTE: EXISTING CONCRETE FLOOR TO REMAIN

WALL LEGEND

- ALL EXISTING WALLS AND DOORS TO REMAIN
- 10'-0" H NEW DRY WALL 1/2" G/WB EACH SIDE OF 3 5/8" STEEL STUDS @ 16" OC
- KINGSPAN KS 45 INSULATED METAL WALL PANEL

Separate Sign Permit is required for any signage